# Clayton Avenue Elementary Final Results (October 2018)

| Sample ID | Floor | Location | Source Type | Result (u g/L or PPB) | Report Received | Plan For Remediation | Sample ID | Result (u g/L or PPB) | Report Received | Sample ID | Result (u g/L or PPB) | Report Received | Sample ID | Result (u g/L or PPB) | Report Received |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| CLA119 | 1 | Upper Cafeteria | Sink 2 | 19.4 | 11/3/2016 | Yes | CLA119-2 | 5.0 | 1/13/17 | | | | | | |
| CLA26 | B | Coaches Office (B) | Sink | 32.5 | 11/3/2016 | Yes | CLA26-2 | 3.2 | 1/13/17 | | | | | | |
| CLA7 | 1 | Room 127 | Sink | 45.3 | 11/3/2016 | Yes | CLA7-2 | 8.1 | 1/13/17 | | | | | | |
| CLA47 | 1 | Classroom 104, BR | Sink | 544 | 11/3/2016 | Yes | CLA47-2 | 295 | 1/13/17 | CLA47-3 | 99 | 4/14/2017 | CLA47-4 | 9 | 7/11/2017 |
| CLA108 | G | EXT Playground Out Bldg. (Women's BR) | Sink 2 | 15 | 11/3/2016 | Yes | CLA108-2 | 16.5 | 1/13/17 | CLA108-3 | 1.5 | 4/14/2017 | | | |