

Re-sampling/ Remediation - Lead In Water at Vestal School District (2023)

VCSD Building	Sample Location	Source Type	Floor	Baseline Testing Date	Delta Sample ID#	Baseline Lab Results (ug/L)	Immediate Action	Re-sampling Testing Date	Delta Sample ID#	Re-sampling Lab Result (ug/L)	Remediation
African Road Elementary (ARE)	Room 156 Coaches Office	Sink	1	5/20/2023	ARE2023-28	10.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
African Road Elementary (ARE)	Kitchen	Mixing Valve Faucet	1	5/20/2023	ARE2023-40	12.1	Disable				
African Road Elementary (ARE)	Kitchen	Sink	1	5/20/2023	ARE2023-41	19.2	Signage				

Central Jr. / Cub Care (CJR)	Kitchen, Room 212	Sink	2	5/18/2023	CJR2023-4	27.3	Signage				
Central Jr. / Cub Care (CJR)	Bathroom 103	Sink	1	5/18/2023	CJR2023-19	11.2	Signage				Not a source of potable water. Warning signs installed.
Central Jr. / Cub Care (CJR)	Room 109 Bathroom	Sink	1	5/18/2023	CJR2023-26	998	Disable	N/A	N/A	N/A	Taken out of service.
Central Jr. / Cub Care (CJR)	Room 109 Bathroom	Sink	1	5/18/2023	CJR2023-27	1060	Disable	N/A	N/A	N/A	Taken out of service.
Central Jr. / Cub Care (CJR)	1st Floor East Hallway	Fountain	1	5/18/2023	CJR2023-30	7.7	Signage				
Central Jr. / Cub Care (CJR)	East Mens Bathroom	Sink	1	5/18/2023	CJR2023-31	11.2	Signage	N/A			Not a source of potable water. Warning signs installed.

Clayton Ave Elementary (CAE)	Room 122, Art	Sink	1	5/18/2023	CLA2023-3	9.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Clayton Ave Elementary (CAE)	Gym Office	Sink	1	5/18/2023	CLA2023-6	10.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Clayton Ave Elementary (CAE)	Upper Cafeteria	Warming Hose	1	5/18/2023	CLA2023-13	49.7	Signage				
Clayton Ave Elementary (CAE)	Coaches Office	Sink	B	5/18/2023	CLA2023-21	7.8	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Clayton Ave Elementary (CAE)	Classroom 103	Fountain	1	5/18/2023	CLA2023-35	8.7	Disable				
Clayton Ave Elementary (CAE)	Classroom 104	Fountain	1	5/18/2023	CLA2023-38	61.3	Disable				
Clayton Ave Elementary (CAE)	Classroom 105, Bathroom	Sink	1	5/18/2023	CLA2023-38	11.5	Signage				
Clayton Ave Elementary (CAE)	Classroom 109	Fountain	1	5/18/2023	CLA2023-43	56.6	Disable				
Clayton Ave Elementary (CAE)	Classroom 109	Sink	1	5/18/2023	CLA2023-54	5.7	Signage				
Clayton Ave Elementary (CAE)	Classroom 201	Sink	2	5/18/2023	CLA2023-68	11.2	Signage				
Clayton Ave Elementary (CAE)	Classroom 213	Sink	1	5/18/2023	CLA2023-95	19.0	Signage				
Clayton Ave Elementary (CAE)	Ext. Playground Out Bldg	Hose Bib 1 [L]	Ext	5/18/2023	CLA2023-101	22.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.

Glenwood Elementary (GLE)	Kitchen	Sink	1	5/19/2023	GLE2023-6	6.6	Signage				
Glenwood Elementary (GLE)	Main Office	Sink	1	5/19/2023	GLE2023-7	6.3	Signage				
Glenwood Elementary (GLE)	Library	Sink	1	5/19/2023	GLE2023-49	16.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Glenwood Elementary (GLE)	Classroom 141	Fountain	1	5/19/2023	GLE2023-65	10.4	Disable				

Tioga Hills Elementary (VHE)	Boiler Room	Sink 1	B	5/16/2023	THE2023-1	15.3	Signage				Not a source of potable water. Warning signs installed.
Tioga Hills Elementary (VHE)	Cafetorium	Sink 3	1	5/16/2023	THE2023-4	7.2	Signage				
Tioga Hills Elementary (VHE)	Girl's Locker Room	Sink 2	1	5/16/2023	THE2023-15	6.6	Signage				Not a source of potable water. Warning signs installed.

Vestal High School (VHS)	Room 279, Teacher's Counter	Sink	2	5/23/2023	VHS2023-25	9.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 277	Sink 5	2	5/23/2023	VHS2023-31	20.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 278, Boy's Bathroom	Sink 3	2	5/23/2023	VHS2023-35	12.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 278A, Girl's Bathroom	Sink 3	2	5/23/2023	VHS2023-38	6.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274 Teacher's Counter	Sink 1	2	5/23/2023	VHS2023-39	14.2	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274	Sink 2	2	5/23/2023	VHS2023-40	62.3	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274	Sink 3	2	5/23/2023	VHS2023-41	11.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.

Vestal High School (VHS)	Room 274	Sink 4	2	5/23/2023	VHS2023-42	20.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274	Sink 5	2	5/23/2023	VHS2023-43	10.9	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274	Sink 6	2	5/23/2023	VHS2023-33	14.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 274A/272A	Sink	2	5/23/2023	VHS2023-35	10.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 272 Teacher’s Counter	Sink 1	2	5/23/2023	VHS2023-49	13.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 272	Sink 3	2	5/23/2023	VHS2023-51	15.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 272	Sink 4	2	5/23/2023	VHS2023-52	16.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 272	Sink 5	2	5/23/2023	VHS2023-53	5.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 265, Teacher’s Counter	Sink 1	2	5/23/2023	VHS2023-71	64.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 265	Sink 6	2	5/23/2023	VHS2023-76	70.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 265	LHS	2	5/23/2023	VHS2023-77	35.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 264 Teacher's Counter	Sink 1	2	5/23/2023	VHS2023-78	9.9	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 264	Sink 3	2	5/23/2023	VHS2023-80	7.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 264	LHS	2	5/23/2023	VHS2023-84	1020.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 263	Sink 1	2	5/23/2023	VHS2023-86	96.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 263	Sink 3	2	5/23/2023	VHS2023-89	53.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 263	LHS	2	5/23/2023	VHS2023-93	32.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 262	Sink 11	2	5/23/2023	VHS2023-110	7.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 262	LHS	2	5/23/2023	VHS2023-111	28.3	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 262A	LHS	2	5/23/2023	VHS2023-113	23.8	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 261	Sink 1	2	5/23/2023	VHS2023-114	45.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 261	Sink 2	2	5/23/2023	VHS2023-115	7.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 261	LHS	2	5/23/2023	VHS2023-120	64.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 260 Lecture Hall	Sink	2	5/23/2023	VHS2023-121	7.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 258	Sink 1	2	5/23/2023	VHS2023-122	72.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 258	LHS	2	5/23/2023	VHS2023-133	33.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 4	2	5/23/2023	VHS2023-139	7.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 5	2	5/23/2023	VHS2023-140	10.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 6	2	5/23/2023	VHS2023-141	40.8	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 8	2	5/23/2023	VHS2023-143	33.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 9	2	5/23/2023	VHS2023-144	27.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	Sink 10	2	5/23/2023	VHS2023-145	20.9	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 256	LHS	2	5/23/2023	VHS2023-147	5.2	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 242B, Girls Bathroom	Sink 1	2	5/23/2023	VHS2023-148	9.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 242A, Boy's Bathroom	Sink 3	2	5/23/2023	VHS2023-153	53.0	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 158, Library Office 1	Sink	1	5/23/2023	VHS2023-175	46.1	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 136B, Girls Bathroom	Sink 3	1	5/23/2023	VHS2023-184	16.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room 135A, Girls Bathroom	Sink 1	1	5/23/2023	VHS2023-194	32.9	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Kitchen, Room 101.2	Sink 3	1	5/23/2023	VHS2023-203	6.4	Signage				
Vestal High School (VHS)	Kitchen, Room 101.2	Sink 4	1	5/23/2023	VHS2023-204	30.8	Signage				
Vestal High School (VHS)	Room 100, Nurse Recovery	Sink 1	1	5/23/2023	VHS2023-216	17.5	Signage				
Vestal High School (VHS)	Room 100.3, Recovery 2	Sink	1	5/23/2023	VHS2023-218	36.2	Signage				
Vestal High School (VHS)	Room A25, Bathroom	Sink	B	5/23/2023	VHS2023-259	13.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room B46	Sink 1	B	5/23/2023	VHS2023-272	5.5	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room B42	Sink 1, Faucet 2	B	5/23/2023	VHS2023-278	20.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.

Vestal High School (VHS)	Room B42	Sink 1, Faucet 2	B	5/23/2023	VHS2023-280	25.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room B40	Sink 2	B	5/23/2023	VHS2023-282	6.3	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal High School (VHS)	Room B48, Dark Room	Sink	B	5/23/2023	VHS2023-294	20.6	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.

Vestal Hills Elementary (VHE)	Room 204 (PE)	Sink	2	5/17/2023	VHE2023-33	20.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
-------------------------------	---------------	------	---	-----------	------------	------	---------	-----	-----	-----	---

Vestal Middle School (VMS)	Boys Bathroom (2) by 213	Sink 3	2	5/20/2023	VMS2023-22	6.7	Signage				Not a source of potable water. Warning signs installed.
Vestal Middle School (VMS)	Room 139	Sink	1	5/20/2023	VMS2023-53	7.9	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal Middle School (VMS)	Room 110	Sink	1	5/20/2023	VMS2023-65	5.7	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.
Vestal Middle School (VMS)	Room 127	Sink 3	1	5/20/2023	VMS2023-90	8.4	Signage	N/A	N/A	N/A	Not a source of potable water. Warning signs installed.

Highlighted fixtures retested below 5.0 ppb following remediation.

Highlighted fixtures final results over 5 PPB & have been taken out of service and are no longer in use.

Highlighted fixtures final results over 5 PPB and are not used for drinking water. Warning signs installed.